GARLAND INDEPENDENT SCHOOL DISTRICT

PURCHASING DEPARTMENT

501 S. Jupiter
Garland, Texas 75042

June 1, 2026

ADDENDUM 1, RFP #133-27

FIRE SUPPRESSION SYSTEM SERVICE FOR STUDENT NUTRITION SERVICES (SNS)

This addendum modifies the original document as listed below and is hereby incorporated to the contract documents. Acknowledge receipt of this addendum by returning the completed and signed form with the solicitation response. Failure to submit the addendum may be used as an evaluated factor.

Question	Answer
1. Recharge/Hydrostatic Test for Each System per specifications – The hydrostatic test charge varies by brand and size. Can we get an idea of what brands are installed for an accurate quote?	The typical cylinder that we have are the Kidde WHDR-260. Another type of cylinder that we have are the Badger RG-2.5Gl.
2. Cap Replacement – This varies by brand – do we have information about what brand is currently being used?	Range Guard system primarily in the district. We also have Kidde/Badger.
3. Hydrostatic Test and Fill - The hydrostatic test charge varies by brand and size. Can we get an idea of what brands are installed for an accurate quote?	Kidde 2.6 Gallon and Badger 2.5 Gallon cylinders.
4. Rebuilding Kit, Wet Valve – Varies by Brand – do we have specifics?	We have Kidde/Badger and Range Guard systems.

Yanet Franco
Yanet Franco
Sr. Buyer

Company Name

Address

City State Zip

Signature

Title